



APPENDIX B RIPLEY COUNTY GOVERNMENT ADA COMPLIANCE EVALUATION)

(SELF

SYSTEM	CORRECTION	DISTRESS	QTY	EST. COST	COMMENTS	PRIORITY	STATUS
COURTHOUSE							
Signage	Front entrance signs are to short	Missing	2	\$20.00	Internal Labor	2	Signs and accessories at BSD and they will build these over the winter
Signage	Special employee entrance rear no signs	Missing	2	\$20.00	Internal Labor	2	Signs and accessories at BSD and they will build these over the winter
Restrooms	1st Floor Bathroom door locks and and requires a key to open	Inadequate	3	\$50.00	Internal Labor	3	Completed 8/AUG/17
Restrooms	1st Floor Bathroom needs plumbing cover under sink	Missing	1	\$30.00	Internal Labor	3	
Signage	Circuit Court no signage in braille (1st entrance)	Missing	2	\$20.00	Internal Labor	2	
Signage	Circuit Court (Judges Office) no signage in braille	Missing	1	\$20.00	Internal Labor	2	
Signage	Superior Court no signage in braille	Missing	2	\$20.00	Internal Labor	2	
Signage	Superior Court (Judges Office) no signage in braille (one entrance)	Missing	1	\$20.00	Internal Labor	2	
Signage	Prosecutors Office no signage in braille	Missing	1	\$20.00	Internal Labor	2	
Signage	Child Support Office no signage in braille	Missing	1	\$20.00	Internal Labor	2	
RIPLEY COUNTY ANNEX BUILDING							
Signage	East side of building	Missing	1	\$20.00	Internal Labor	2	Signs and accessories at BSD and they will build these over the winter
Signage	Health Department entrance	Missing	2	\$20.00	Internal Labor	2	Signs and accessories at BSD and they will build these over the winter
FAIRGROUNDS - EXTENSION OFFICE							
Parking	Extension Office no handicap sign	Missing	1	\$21.00	Internal Labor	1	Signs and accessories at BSD and they will build these over the winter
Counters	Counter Service is taller than 36in	Inadequate	1	BID		2	
Restrooms	No handicap accessible signs on outside doors	Inadequate	1	\$21.00	Internal Labor	3	Completed 27/July/17
Restrooms	No handicap accessible signs on restroom door	Inadequate	1	\$21.00	Internal Labor	3	On order
FAIRGROUNDS BUILDING 1							

Parking	Building no handicap parking signs	Missing	5	Combined Project	Internal Labor	1	Signs and accessories at BSD and they will build these over the winter
FAIRGROUNDS BUILDING 16							
Parking	Building 16 No designated handicap parking	Missing	1	Combined Project	Internal Labor	1	Signs and accessories at BSD and they will build these over the winter
Restrooms	Building 16 bathroom needs to lower mirror	Inadequate	1	0	Internal Labor	3	
Restrooms	Building 16 needs to replace doorknob with lever	Inadequate	1	\$50.00	Internal Labor	3	
Restrooms	Building 16 needs to have clearance under the sink	Inadequate	1	0	Internal Labor	3	
Bleachers	Mark handicap spot in bleachers	Missing	2	\$21.00	Internal Labor	2	
Restrooms	Central restroom building need to mark stalls and building with handicap signs	Missing	1	\$21.00	Internal Labor	3	
Restrooms	Central restroom building need to replace door handles with levers	Inadequate	1	\$50.00	Internal Labor	3	
Restrooms	Central restroom building need to paint or mark/block of drop off on the west side	Missing	1	\$21.00	Internal Labor	3	
Restrooms	Building 7A need to mark stalls and building with handicap signs	Missing	1	\$21.00	Internal Labor	3	
Restrooms	Building 7A need to replace door handles with levers	Inadequate	1	\$50.00	Internal Labor	3	
Restrooms	Building 7A step to bathroom is not flat	Inadequate	1	BID		3	
Parking	Need handicap parking signs	Missing	2	Combined Project	Internal Labor	1	Signs and accessories at BSD and they will build these over the winter
RC HIGHWAY							
Entrance	Front entrance needs to be level	Inadequate	1	BID		1	
Entrance	Office door handles need to be levers	Inadequate	2	\$100.00	Internal Labor	2	Completed 18/August/17
Entrance	Needs a handicap sign	Missing	1	\$21.00	Internal Labor	1	Pending install December 2018
Restrooms	Needs a handrail	Missing	1	\$40.00	Internal Labor	3	
Restrooms	Need space under sink	Inadequate	1	0	Internal Labor	3	
Restrooms	Mirror needs to be lowered	Inadequate	1	0	Internal Labor	3	
Restrooms	Dispensor needs to be lowered	Inadequate	1	0	Internal Labor	3	
Restrooms	Cabinets across toilet need to be moved higher (room)	Inadequate	1	0	Internal Labor	3	
Restrooms	Bathroom door handle needs to be a lever	Inadequate	1	\$50.00	Internal Labor	3	
RECYCLE CENTER							
Entrance	Ramp to work release door in not flat	Inadequate	1	BID		1	

SHERIFF BUILDING/JAIL							
Entrance	Ramp to work release door in not flat	Inadequate	1	BID	This door is not in use for employees or work release	1	
Entrance	Front of jail needs designated parking spot	Inadequate	1	0	Need to move in front of building versus the side	1	Completed 28/August/18
Entrance	Sidewalk is not flat and has a gap (sidewalk) over 1/2 inches	Inadequate	1	BID		1	
RCEMS BUILDING/MILAN							
Entrance	Needs designated parking spot	Inadequate	1	\$21.00	Internal Labor	1	Signs and accessories at BSD and they will build these over the winter
Restrooms	Mirror needs to be lowered	Inadequate	1	0	Internal Labor	3	
Restrooms	Cabinets across toilet need to be moved higher (room)	Inadequate	1	0	Internal Labor	3	
Restrooms	Bathroom door handle needs to be a lever	Inadequate	1	\$50.00	Internal Labor	3	
Office	Handle needs to be a lever	Inadequate	2	\$50.00	Internal Labor	2	